

TEST ATTESTATION

Contract No.: 1341/2016/8 – BF

08.06.2016
ROH/MAM

Customer: EVVA Sicherheitstechnologie GmbH
Wienerbergstraße 59-65
AT-1120 Wien

Subject: Evaluation of existing locking cylinders type DPI, DPX and DPS, DPI (ZH), DPS (ZH), DPX (ZH), ICS, 3 KS, 3 KS+, ALS, EPS, EPSxp, EPS (ZH), EPSxp (ZH) in respect of ÖNORM EN 1303:2015, ÖNORM B 5356:1998 and ÖNORM B 5351:2011

Result: According to the Expert's report No. 1341/2016 and therein cited verifications Holzforschung Austria confirms, that the profile cylinders type ICS fulfil the requirements of ÖNORM EN 1303:2015, ÖNORM B 5356:1998 and ÖNORM B 5351:2011.

Classification to ÖNORM EN 1303, issue: July 2015:

Category of use	1
Test cycles / Durability	6
Door mass	0
Fire resistance	B
Safety	0
Corrosion resistance and temperature	C
Key related security	6
Attack resistance	D ¹⁾

Classification according ÖNORM B 5351, issue: September 2011
clause 4.2, 5.2 and 6.3 in resistance class W_Z 6-BZ


¹⁾ Attack resistance class D only in combination with a suitable security furniture or rosette (escutcheon), cylinder projection maximum 3,0 mm.

Period of validity: --

HOLZFORSCHUNG AUSTRIA


Hubert Romirer, Bakk. techn.
Technical consultant




DI Martin Wieser

In case of dispute the original German version prevails. This translation is for information purposes only.