

TEST ATTESTATION

Contract No.: 558/2016 - BF 02.03.2016
ROH/PIK

Customer: EVVA Sicherheitstechnologie GmbH
Wienerbergstraße 59-65
AT-1120 Wien

Subject: Evaluation of locking cylinders type MCS-rk modular construction on the basis of already tested types with modified design in respect of ÖNORM EN 1303, ÖNORM B 5351 and ÖNORM B 5356

Result: According to the Expert's report No. 558/2016 and therein cited verifications Holzforschung Austria confirms, that the profile cylinders type MCS-rk with modified drilling protection fulfil the requirements of ÖNORM EN 1303:2015; ÖNORM B 5356:1998 and ÖNORM B 5351:2011.

Classification to ÖNORM EN 1303, issue: July 2015:

Category of use	1
Test cycles/Durability	6
Door mass	0
Fire resistance	B
Safety	0
Corrosion resistance and temperature	C
Key related security	6
Attack resistance	D ¹⁾

Classification according ÖNORM B 5351, issue: September 2011 clause 4.2, 5.2 and 6.3 in resistance class W₂ 6-BZ

¹⁾ Attack resistance class D only in combination with a suitable security furniture or rosette (escutcheon), cylinder projection maximum 3 mm.

Period of validity: --

HOLZFORSCHUNG AUSTRIA


Hubert Romirer, Bakk. techn.
Technical consultant




DI Martin Wieser

In case of dispute the original German version prevails. This translation is for information purposes only.